

2019 AWWA Water Audit Level 1 Validation – Review Document

Audit Information:

Utility: San Lorenzo Valley Water District **PWS ID:** 4410014
System Type: Potable **Audit Period:** Calendar 2019
Utility Representation: James Furtado (Deputy Director of Operations)
Validation Date: 6/25/2020 **Call Time:** 8:30am **Sufficient Supporting Documents Provided:** Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 50 **Data Validity Band (Level):** Band II (26-50)
ILI: 1.79 **Real Loss:** 46.01 (gal/conn/day) **Apparent Loss:** 2.66 (gal/conn/day)
Non-revenue water as percent of cost of operating system: 2.7%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Larry Lewison, Drew Blackwell **Validator Qualifications:** Contractor for California Water Loss TAP

Validator Provided